

PERIODIC INSPECTION REPORT FOR AN ELECTRICAL INSTALLATION

Issued in accordance with *British Standard 7671 - Requirements for Electrical Installations* by an Approved Contractor or Conforming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable LU5 5ZX

Original (To the person ordering the work)

A. DETAILS OF THE CLIENT

Client: Burtle Village Hall Address: Burtle village hall
Burtle
Bridgwater TA7 8NB

B. PURPOSE OF THE REPORT

This Periodic Inspection Report must be used only for reporting on the condition of an existing installation.

Purpose for which this report is required: For the safety of the 230v fixed installation and the people using it

C. DETAILS OF THE INSTALLATION

Occupier: — Description of premises: Domestic Commercial Industrial

Address: Burtle Village Hall
Burtle
Bridgwater Other: (Please state) Public Room

Postcode: TA7 8NB Estimated age of the electrical installation: 8 years

Date of previous inspection: 19/06/2009 Electrical Installation Certificate No or previous Periodic Inspection Report No: HC/1057

Records of installation available: Evidence of alterations or additions If yes, estimated age 81-5 years

Records held by: Bill Dean - Burtle village hall -

D. EXTENT OF THE INSTALLATION AND LIMITATIONS OF THE INSPECTION AND TESTING

Extent of the electrical installation covered by this report:
the whole 230v fixed installation

Agreed limitations (including the reasons), if any, on the inspection and testing:
30% test readings taken
30% F.Hings removed for re-test

This inspection has been carried out in accordance with BS 7671, as amended. Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric of the building or underground, have not been visually inspected.

E. DECLARATION

I/We, being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above (see C), having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations (see F) and the attached schedules (see H), provides an accurate assessment of the condition of the electrical installation taking into account the stated extent of the installation and the limitations of the inspection and testing (see D).
I/We further declare that in my/our judgement, the said installation was overall in Satisfactory condition (see G) at the time the inspection was carried out, and that it should be further inspected as recommended (see I).
* (Insert 'a satisfactory' or 'an unsatisfactory', as appropriate)

INSPECTION, TESTING AND ASSESSMENT BY:

Signature: AW

Name: (CAPITALS) ANDREW BISCRONE

Position: Electrician

Date: 24.4.17

REPORT REVIEWED AND CONFIRMED BY: † See note below

Signature: AW

Name: (CAPITALS) ANDREW BISCRONE
(Registered Qualified Supervisor for the Approved Contractor at J)

Date: 24.4.17

† This Periodic Inspection Report should be reviewed and confirmed by the registered Qualified Supervisor for the Approved Contractor responsible for issuing the Report.